



INSPECTION REPORT

检测报告书

山东仁丰特种材料股份有限公司

地址：山东省淄博市桓台县起凤镇南首仁丰路1号 邮编：256407

TEL: +86-533-8688836

FAX: +86-533-8698158

Website: www.zbrenfeng.com

Test Date: 2020-11-06

Model: (产品) 高效过滤器	Size: (尺寸) 595*595*95mm
Oty: (数量) 1 PCS	

Sampling Rate(抽样标准): 委托全检	Air Quantity: (风量) 1700m³/h
---------------------------	-----------------------------

Inspection Items & Result 检测项目&结果			
Items (项目)	Unit (单位)	Result (结果)	Target (目标)
Frame (边框)		OK	
Filter Media (滤料)		OK	
Gasket (垫片)		OK	
PU (密封胶)		OK	
Label (标签)		OK	
Outline Size (外形尺寸)	mm	OK	
Leakage Test(泄露测试)		Pass	Leak free
Efficiency@0.3um(效率)	%	99.9823	≥ 99.97%
Initial Resistance@1000CMH (初阻力)	Pa	65.5	≤ 125Pa

1、实验条件：温度 23±5℃，湿度 50±10%
Test conditions: temperature 23±5℃, moisture 50±10%

2、以上效率和阻力采用 TSI-8130AG 仪器检测
The Pressure Drop and Efficiency are tested by TSI-8130AG.

Conclusion(结论)
The products of data are meets the requirement

TEST UNDER IEST/EN1822 STANDARD

Certificate
合格证明

RF certifies that above products are qualified by strictly inspected and tested according to it's sepecification.

RF 保证以上产品是经过严格检验及测试的合格产品。

检验员：鲁洪霞

审核：吕建莉